

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect; the co

DRYTYPE	CITY/TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION	SAMPLE LOCATION NAME	MPLE CODE	ANALYTE NAME	RESULT	U OF MEASURE	METHOD DETECTION LIMIT	ANALYTICAL METHOD	ANALYSIS L	LAB SAMPLE ID
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	001F	B114 Kitchen Sink faucet	KC	COPPER	0.6276	MG/L	.01	EPA 200.8	CAL	L1630852-02
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	001F	B114 Kitchen Sink faucet	KC	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-02
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	001P	B114 Kitchen Sink faucet	KC	COPPER	0.5291	MG/L	.01	EPA 200.8	CAL	L1630852-01
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	001P	B114 Kitchen Sink faucet	KC	LEAD	0.00160	MG/L	.001	EPA 200.8	CAL	L1630852-01
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	002F	B100 faucet	CF	COPPER	0.3878	MG/L	.001	EPA 200.8	CAL	L1630852-04
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	002F	B100 faucet	CF	LEAD	0.00151	MG/L	.001	EPA 200.8	CAL	L1630852-04
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	002P	B100 faucet	CF	COPPER	0.5598	MG/L	.01	EPA 200.8	CAL	L1630852-03
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	002P	B100 faucet	CF	LEAD	0.00411	MG/L	.001	EPA 200.8	CAL	L1630852-03
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	003F	B111 faucet	CF	COPPER	0.4782	MG/L	.01	EPA 200.8	CAL	L1630852-06
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	003F	B111 faucet	CF	LEAD	0.00129	MG/L	.001	EPA 200.8	CAL	L1630852-06
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	003P	B111 faucet	CF	COPPER	0.6669	MG/L	.01	EPA 200.8	CAL	L1630852-05
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	003P	B111 faucet	CF	LEAD	0.00191	MG/L	.001	EPA 200.8	CAL	L1630852-05
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	004P	B111 ice maker	KI	COPPER	0.01811	MG/L	.001	EPA 200.8	CAL	L1630852-07
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	004P	B111 ice maker	KI	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-07
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	005F	WC across from B103 Left	WC	COPPER	0.3776	MG/L	.001	EPA 200.8	CAL	L1630852-09
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	005F	WC across from B103 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-09
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	005P	WC across from B103 Left	WC	COPPER	0.6910	MG/L	.01	EPA 200.8	CAL	L1630852-08
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	005P	WC across from B103 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-08
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	006F	WC across from B103 Right	WC	COPPER	0.4266	MG/L	.001	EPA 200.8	CAL	L1630852-11
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	006F	WC across from B103 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-11
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	006P	WC across from B103 Right	WC	COPPER	0.4365	MG/L	.001	EPA 200.8	CAL	L1630852-10
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	006P	WC across from B103 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-10
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	007F	SC-B113A	SC	COPPER	1.304	MG/L	.01	EPA 200.8	CAL	L1630852-13
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	007F	SC-B113A	SC	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-13
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	007P	SC-B113A	SC	COPPER	0.6114	MG/L	.01	EPA 200.8	CAL	L1630852-12
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	007P	SC-B113A	SC	LEAD	0.00658	MG/L	.001	EPA 200.8	CAL	L1630852-12
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	008F	B239 faucet	CF	COPPER	0.3682	MG/L	.001	EPA 200.8	CAL	L1630852-15
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	008F	B239 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	CAL	L1630852-15
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	008P	B239 faucet	CF	COPPER	0.5565	MG/L	.01	EPA 200.8	CAL	L1630852-14
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	008P	B239 faucet	CF	LEAD	0.00453	MG/L	.001	EPA 200.8	CAL	L1630852-14

LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	009F	WC across from B231 left	WC	COPPER	0.4489	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-17
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	009F	WC across from B231 left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-17
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	009P	WC across from B231 left	WC	COPPER	0.6063	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-16
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	009P	WC across from B231 left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-16
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	010F	WC across from B231 right	WC	COPPER	0.3460	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-19
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	010F	WC across from B231 right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-19
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	010P	WC across from B231 right	WC	COPPER	0.5668	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-18
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	010P	WC across from B231 right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-18
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	011F	WC across from B227 left	WC	COPPER	0.8042	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-21
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	011F	WC across from B227 left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-21
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	011P	WC across from B227 left	WC	COPPER	0.9872	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-20
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	011P	WC across from B227 left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-20
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	012F	WC across from B227 right	WC	COPPER	0.7240	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-23
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	012F	WC across from B227 right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-23
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	012P	WC across from B227 right	WC	COPPER	0.8291	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-22
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	012P	WC across from B227 right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-22
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	013F	Kitchen faucet coffee area	KC	COPPER	0.5635	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-25
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	013F	Kitchen faucet coffee area	KC	LEAD	0.0032	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-25
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	013P	Kitchen faucet coffee area	KC	COPPER	0.7601	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-24
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	013P	Kitchen faucet coffee area	KC	LEAD	0.0448	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-24
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	014F	Kitchen Kettle	KK	COPPER	0.2778	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-27
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	014F	Kitchen Kettle	KK	LEAD	0.0030	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-27
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	014P	Kitchen Kettle	KK	COPPER	0.3038	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-26
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	014P	Kitchen Kettle	KK	LEAD	0.0098	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-26
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	015F	Kitchen Kettle	KK	COPPER	0.5908	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-29
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	015F	Kitchen Kettle	KK	LEAD	0.0016	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-29
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	015P	Kitchen Kettle	KK	COPPER	0.2613	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-28
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	015P	Kitchen Kettle	KK	LEAD	0.0094	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-28
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	016F	Kitchen prep sink B229	KC	COPPER	0.3770	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-31
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	016F	Kitchen prep sink B229	KC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-31
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	016P	Kitchen prep sink B229	KC	COPPER	0.6371	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-30
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	016P	Kitchen prep sink B229	KC	LEAD	0.0024	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-30

LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	017P	Kitchen ice maker B242E	KI	COPPER	0.0424	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-32
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	017P	Kitchen ice maker B242E	KI	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-32
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	018F	B326F faucet, cold	KC	COPPER	0.6986	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-34
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	018F	B326F faucet, cold	KC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-34
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	018P	B326F faucet, cold	KC	COPPER	0.4955	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-33
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	018P	B326F faucet, cold	KC	LEAD	0.0020	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-33
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	019F	B321A faucet	CF	COPPER	0.4183	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-36
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	019F	B321A faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-36
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	019P	B321A faucet	CF	COPPER	0.6412	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-35
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	019P	B321A faucet	CF	LEAD	0.0022	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-35
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	020F	B323B faucet	CF	COPPER	0.5672	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-38
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	020F	B323B faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-38
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	020P	B323B faucet	CF	COPPER	0.6361	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-37
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	020P	B323B faucet	CF	LEAD	0.0024	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-37
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	021F	B440 faucet	CF	COPPER	0.9861	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-40
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	021F	B440 faucet	CF	LEAD	0.0012	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-40
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	021P	B440 faucet	CF	COPPER	0.7686	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-39
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	021P	B440 faucet	CF	LEAD	0.0036	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-39
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	022F	B472 faucet	CF	COPPER	0.8133	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-42
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	022F	B472 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-42
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	022P	B472 faucet	CF	COPPER	0.6453	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-41
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	022P	B472 faucet	CF	LEAD	0.0021	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-41
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	023F	WC (467-468) Left	WC	COPPER	0.4173	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-44
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	023F	WC (467-468) Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-44
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	023P	WC (467-468) Left	WC	COPPER	0.8820	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-43
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	023P	WC (467-468) Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-43
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	024F	WC (467-468) Right	WC	COPPER	0.5348	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-46
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	024F	WC (467-468) Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-46
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	024P	WC (467-468) Right	WC	COPPER	0.4435	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-45
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	024P	WC (467-468) Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-45
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	025F	B465 faucet	CF	COPPER	0.5913	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-48
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	025F	B465 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-48

LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	025P	B465 faucet	CF	COPPER	0.5784	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-47
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	025P	B465 faucet	CF	LEAD	0.0020	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-47
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	026F	C124 faucet	CF	COPPER	0.8265	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-50
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	026F	C124 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-50
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	026P	C124 faucet	CF	COPPER	0.4518	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-49
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	026P	C124 faucet	CF	LEAD	0.0030	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-49
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	027F	WC across from C123 Left	WC	COPPER	0.6084	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-52
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	027F	WC across from C123 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-52
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	027P	WC across from C123 Left	WC	COPPER	0.8130	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-51
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	027P	WC across from C123 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-51
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	028F	WC across from C123 Right	WC	COPPER	0.6654	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-54
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	028F	WC across from C123 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-54
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	028P	WC across from C123 Right	WC	COPPER	0.6184	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-53
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	028P	WC across from C123 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-53
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	029F	WC C200's hallway Left	WC	COPPER	1.216	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-56
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	029F	WC C200's hallway Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-56
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	029P	WC C200's hallway Left	WC	COPPER	1.262	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-55
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	029P	WC C200's hallway Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-55
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	030F	WC C200's hallway Right	WC	COPPER	0.9589	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-58
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	030F	WC C200's hallway Right	WC	LEAD	0.001	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-58
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	030P	WC C200's hallway Right	WC	COPPER	1.076	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-57
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	030P	WC C200's hallway Right	WC	LEAD	0.0011	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-57
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	031F	C252E faucet	CF	COPPER	0.6900	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-60
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	031F	C252E faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-60
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	031P	C252E faucet	CF	COPPER	0.6191	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-59
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	031P	C252E faucet	CF	LEAD	0.0025	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-59
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	032F	C387 faucet	CF	COPPER	1.302	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-62
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	032F	C387 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-62
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	032P	C387 faucet	CF	COPPER	0.9652	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-61
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	032P	C387 faucet	CF	LEAD	0.00182	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-61
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	033F	WC across from C343 Left	WC	COPPER	0.6122	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-64
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	033F	WC across from C343 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-64

LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D33P	WC across from C343 Left	WC	COPPER	0.7908	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-63
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D33P	WC across from C343 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-63
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D34F	WC across from C343 Right	WC	COPPER	0.7379	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-66
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D34F	WC across from C343 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-66
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D34P	WC across from C343 Right	WC	COPPER	0.5801	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-65
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D34P	WC across from C343 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-65
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D35F	C376 faucet	CF	COPPER	0.3053	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-68
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D35F	C376 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-68
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D35P	C376 faucet	CF	COPPER	0.3241	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-67
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D35P	C376 faucet	CF	LEAD	0.00711	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-67
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D35F	WC across from A200 Left	WC	COPPER	0.6098	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-70
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D36F	WC across from A200 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-70
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D36P	WC across from A200 Left	WC	COPPER	1.199	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-69
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D36P	WC across from A200 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-69
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D37F	WC across from A200 Right	WC	COPPER	0.6547	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-72
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D37F	WC across from A200 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-72
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D37P	WC across from A200 Right	WC	COPPER	0.7004	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-71
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D37P	WC across from A200 Right	WC	LEAD	0.00116	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-71
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D39F	A220 faucet	CF	COPPER	0.6757	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-74
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D39F	A220 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-74
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D39P	A220 faucet	CF	COPPER	1.167	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-73
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D39P	A220 faucet	CF	LEAD	0.00150	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-73
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D40F	A205 faucet	CF	COPPER	1.058	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-76
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D40F	A205 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-76
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D40P	A205 faucet	CF	COPPER	0.9931	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-75
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D40P	A205 faucet	CF	LEAD	0.00235	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-75
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D42F	WC across from A300 Left	WC	COPPER	0.5734	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-78
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D42F	WC across from A300 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-78
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D42P	WC across from A300 Left	WC	COPPER	0.7954	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-77
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D42P	WC across from A300 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-77
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D43F	WC across from A300 Right	WC	COPPER	0.5288	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-80
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	D43F	WC across from A300 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-80

LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	043P	WC across from A300 Right	WC	COPPER	0.5712	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-79
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	043P	WC across from A300 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-79
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	044F	WC across from A309 Left	WC	COPPER	0.7290	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-82
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	044F	WC across from A309 Left	WC	LEAD	0.00112	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-82
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	044P	WC across from A309 Left	WC	COPPER	1.009	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-81
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	044P	WC across from A309 Left	WC	LEAD	0.00154	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-81
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	045F	WC across from A309 Right	WC	COPPER	0.5930	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-84
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	045F	WC across from A309 Right	WC	LEAD	0.00102	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-84
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	045P	WC across from A309 Right	WC	COPPER	0.8520	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-83
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	045P	WC across from A309 Right	WC	LEAD	0.00104	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-83
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	046F	A309A faucet	CF	COPPER	0.4603	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-86
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	046F	A309A faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-86
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	046P	A309A faucet	CF	COPPER	0.6615	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-85
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	046P	A309A faucet	CF	LEAD	0.00246	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-85
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	047F	A314 faucet	NS	COPPER	0.7052	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-88
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	047F	A314 faucet	NS	LEAD	0.00100	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-88
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	047P	A314 faucet	NS	COPPER	0.7319	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-87
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	047P	A314 faucet	NS	LEAD	0.00366	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-87
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	048F	A313A faucet	NS	COPPER	0.2050	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-90
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	048F	A313A faucet	NS	LEAD	0.00138	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-90
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	048P	A313A faucet	NS	COPPER	0.2751	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-89
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	048P	A313A faucet	NS	LEAD	0.01241	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-89
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	049F	A318 faucet	CF	COPPER	0.8351	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-92
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	049F	A318 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-92
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	049P	A318 faucet	CF	COPPER	0.7913	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-91
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	049P	A318 faucet	CF	LEAD	0.00195	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-91
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	050F	A305 faucet	CF	COPPER	0.7968	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-94
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	050F	A305 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-94
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	050P	A305 faucet	CF	COPPER	0.8460	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-93
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	050P	A305 faucet	CF	LEAD	0.00241	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-93
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	051P	A313A ice maker	KI	COPPER	0.1960	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-95
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	051P	A313A ice maker	KI	LEAD	0.00824	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-95

LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	052P	A417 ice maker	XI	COPPER	0.1188	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-96
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	052P	A417 ice maker	XI	LEAD	0.00158	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-96
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	053F	A421 faucet	CF	COPPER	1.101	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-98
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	053F	A421 faucet	CF	LEAD	0.00557	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-98
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	053P	A421 faucet	CF	COPPER	0.8873	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-97
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	053P	A421 faucet	CF	LEAD	0.00285	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-97
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	054F	A422 faucet	CF	COPPER	1.050	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-100
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	054F	A422 faucet	CF	LEAD	0.00455	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-100
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	054P	A422 faucet	CF	COPPER	0.8414	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-99
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	054P	A422 faucet	CF	LEAD	0.00597	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-99
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	055F	A423 faucet	CF	COPPER	1.064	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-102
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	055F	A423 faucet	CF	LEAD	0.00464	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-102
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	055P	A423 faucet	CF	COPPER	0.8578	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-101
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	055P	A423 faucet	CF	LEAD	0.00430	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-101
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	056F	A424 faucet	CF	COPPER	1.013	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-104
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	056F	A424 faucet	CF	LEAD	0.00488	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-104
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	056P	A424 faucet	CF	COPPER	0.8323	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-103
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	056P	A424 faucet	CF	LEAD	0.00586	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-103
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	057F	Water cooler by A426 Left	WC	COPPER	0.6375	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-106
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	057F	Water cooler by A426 Left	WC	LEAD	0.00139	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-106
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	057P	Water cooler by A426 Left	WC	COPPER	0.7609	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-105
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	057P	Water cooler by A426 Left	WC	LEAD	0.00156	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-105
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	058F	Water cooler by A426 Right	WC	COPPER	0.6006	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-108
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	058F	Water cooler by A426 Right	WC	LEAD	0.00127	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-108
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	058P	Water cooler by A426 Right	WC	COPPER	0.6327	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-107
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	058P	Water cooler by A426 Right	WC	LEAD	0.00151	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-107
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	059F	Water cooler by A429 Left	WC	COPPER	1.083	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-110
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	059F	Water cooler by A429 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ANALYTI CAL	L1630852-110
LCCA	Sudbury	06950505	Lincoln-Sudbury: Lincoln-Sudbury Regional High	Public School	059P	Water cooler by A429 Left	WC	COPPER	0.8742	MG/L	.01	EPA 200.8	ANALYTI CAL	L1630852-109

LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	059P	Water cooler by A429 Left	WC	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-109
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	060F	Water cooler by A429 Right	WC	COPPER	0.7920	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-112
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	060F	Water cooler by A429 Right	WC	LEAD	0.00115	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-112
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	060P	Water cooler by A429 Right	WC	COPPER	0.9321	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-111
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	060P	Water cooler by A429 Right	WC	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-111
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	061F	A428 faucet	CF	COPPER	0.6324	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-114
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	061F	A428 faucet	CF	LEAD	0.00475	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-114
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	061P	A428 faucet	CF	COPPER	1.006	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-113
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	061P	A428 faucet	CF	LEAD	0.00339	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-113
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	062F	A427 faucet	CF	COPPER	0.5766	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-116
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	062F	A427 faucet	CF	LEAD	0.00479	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-116
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	062P	A427 faucet	CF	COPPER	0.8984	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-115
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	062P	A427 faucet	CF	LEAD	0.00794	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-115
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	063F	A435 faucet	CF	COPPER	1.042	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-118
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	063F	A435 faucet	CF	LEAD	0.00353	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-118
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	063P	A435 faucet	CF	COPPER	0.7940	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-117
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	063P	A435 faucet	CF	LEAD	0.00336	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-117
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	064F	A434 faucet	CF	COPPER	1.139	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-120
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	064F	A434 faucet	CF	LEAD	0.00232	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-120
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	064P	A434 faucet	CF	COPPER	0.9636	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-119
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	064P	A434 faucet	CF	LEAD	0.00270	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL L1630852-119
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Lincoln-Sudbury Regional High	Public School	065F	A401 faucet	CF	COPPER	0.6363	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL L1630852-122

LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	065F	A401 faucet	CF	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-122
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	065P	A401 faucet	CF	COPPER	0.6774	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-121
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	065P	A401 faucet	CF	LEAD	0.00171	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-121
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	066F	WC NEXT TO B340 L	WC	COPPER	0.5227	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-124
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	066F	WC NEXT TO B340 L	WC	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-124
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	066P	WC NEXT TO B340 L	WC	COPPER	0.7792	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-123
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	066P	WC NEXT TO B340 L	WC	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-123
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	067F	WC NEXT TO B340 L	WC	COPPER	0.5711	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-126
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	067F	WC NEXT TO B340 L	WC	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-126
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	067P	WC NEXT TO B340 L	WC	COPPER	0.6043	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-125
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	067P	WC NEXT TO B340 L	WC	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-125
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	068F	WC NEXT TO B340 R	CF	COPPER	0.7096	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-128
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	068F	WC NEXT TO B340 R	CF	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-128
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	068P	WC NEXT TO B340 R	CF	COPPER	0.6208	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-127
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	068P	WC NEXT TO B340 R	CF	LEAD	0.01093	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-127
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	069F	WC NEXT TO B340 R	CF	COPPER	0.7821	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-130
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	069F	WC NEXT TO B340 R	CF	LEAD	ND	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-130
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	069P	WC NEXT TO B340 R	CF	COPPER	0.6715	MG/L	.01	EPA 200.8	ALPHA ANALYTICAL	11630852-129
LCCA	Sudbury	06950505	Lincoln-Sudbury Regional High	Public School	069P	WC NEXT TO B340 R	CF	LEAD	0.00334	MG/L	.001	EPA 200.8	ALPHA ANALYTICAL	11630852-129